

Watson-Marlow 620SN/R Manual Control Variable Speed Peristaltic Pump

Part 1 - General

1.01 Description

- A. Pumps shall be positive displacement peristaltic type complete with retractable roller pumphead, self-contained variable speed drive, and flexible extruded tube as specified.
- B. Peristaltic pumping action is created by the compression of the flexible tube between the pumphead rollers and track, induced forward fluid displacement within the tube by the rotation of the pump rotor, and subsequent vacuum-creating restitution of the tube.
- C. Pumps shall be dry self-priming, capable of being run dry without damaging effects to pump or tube, and shall have a maximum suction lift capability of up to 30' vertical water column. Maximum pressure rating: 30 psi.
- D. Pump shall not use check valves or diaphragms and shall not require dynamic seals in contact with the pumped fluid. Process fluid shall be contained within pump tubing and shall not directly contact any rotary or metallic components.
- E. Flow shall be in the direction of the rotor rotation, which can be reversed and shall be proportional to rotor speed.

1.02 Quality Assurance

- A. This specification is the basis for design of peristaltic metering pumps. All pumps, whether named as an acceptable supplier, or submitted as an equal must, at a minimum, meet the following critical design requirements.
- B. To maximize pump efficiency and minimize tube fatigue that will impact life, performance, and accuracy, pumps must be designed not to exceed a P/10 ratio (Theoretical maximum number of occlusions per 10 gallons pumped). Pumps exceeding the specified P/10 ratio will not be considered suitable for the duty condition. The following criteria is set to maintain the P/10 of ratio for the tube size specified for this application:
 1. Maximum two compressing rollers for two compressions per revolution.
 2. Tube wall thickness of 3.2 mm and material specified
 3. Large diameter spring-loaded roller set for 3.2mm wall thickness tubing
 4. Max base drive speed of 265 RPM for 3.2mm wall thickness tubing.
 5. Track geometry of no less than 180 degrees and rotor geometry with roller 180 degrees apart.
- C. P/10 ratio shall not exceed the following per tube size:

Tube Size	P/10 ratio
6.4mm x 3.2mm	5,848
9.6mm x 3.2mm	3,022
12.7mm x 3.2mm	1,892
15.9mm x 3.2mm	1,580
- D. For quality assurance, all pump tubing must be manufactured by the pump manufacturer in accordance with their specifications. Tubing not manufactured by the pump manufacturer will not be acceptable.
- E. For chemical compatibility with a broad spectrum of chemicals, the pump housing shall have powder coating per 2.03.C.5.
- F. Pumps to be manufacturer's standard product. Manufacturer of tubing pumps must have at least 20 operating installations in domestic water or wastewater treatment plants located in the United States over a period of at least five years in the same service and size as specified.

- G. Drive and pump heads shall be 24 hr continuous duty rated and have a five-year manufacturer's warranty from date of shipment.
- H. Pumps must be manufactured under ISO 9001-2000.
- I. Pumps shall meet all applicable CE and C ETL US standards per UL610101A

1.03 Submittals

A. Submit the following

1. Certified shop drawings.
2. Characteristic performance curve showing flow rate as a function of RPM and pressure.
3. Dimensional drawings.
4. Operating, maintenance, programming, and wiring instructions
5. P/10 ratio calculation.

1.04 Delivery, Storage, & Handling

A. Shipping

1. Ship pump and drive assembled complete. Ship tubing separately packed in a continuous length. Required length for installation shall be cut by the Contractor, with the remaining tubing stored for spare replacement.
2. Pack all additional spare parts in containers bearing labels clearly designating contents and pieces of equipment for which intended.
3. Deliver spare parts at the same time as pertaining equipment.

B. Receiving

1. Contractor to inspect and inventory items upon delivery to site.
2. Contractor to store and safeguard equipment, material, instructions, and spare parts in accordance with manufacturer's written instructions.

Part 2 - Pump Design

2.01 Manufacturers

A. Watson-Marlow, Inc.

2.02 Pump Process Schedule

Quantity	*(Engineer to specify)*			
Tag Number(s)	*(Engineer to specify)*			
Fluid Viscosity Specific Gravity Fluid Temperature	*(Engineer to specify)*			
Tubing Material	Marprene II *(Alternate material available upon request)*			
Max – Min Capacity (GPH)	*(Engineer to specify)*			
Max Pump RPM for Application	*(Engineer to specify)*			
Tubing ID *(Engineer to specify)*	6.4mm	9.6mm	12.7mm	15.9mm
Displacement /Revolution (Gallons)	0.00342	0.00662	0.01058	0.01267
Displacement /Revolution (Liters)	0.013	0.025	0.040	0.048

P10 Ratio (Theoretical Maximum Number of Occlusions/10 Gallons Pumped)	5,848	3,022	1,892	1,580
Min Flow Rate (GPM)	0.0003	0.0007	0.0011	0.0013
Max Flow Rate (GPM)	0.91	1.75	2.80	3.36
Min Flow Rate (LPM)	0.0013	0.0025	0.0040	0.0048
Max Flow Rate (LPM)	3.45	6.63	10.6	12.72
Max Discharge Pressure (PSI)	*(Engineer to specify)*			
Suction Head	*(Engineer to specify)*			
Power (VAC, Frequency, Phase)	115VAC, 60 Hz, 1 Phase			

2.03 Pump Construction

A. Pumphead

1. Pumphead shall consist of a fixed track with tool lockable-hinged guard door and magnetic safety interlock, which shall render the drive inoperable when the pump door is open. For operator safety, pumps without lockable guard, safety interlock, and/or flip-top design pump heads are not acceptable.
2. Pumphead door shall have two clear windows for viewing of rotation direction. When closed, pump door shall seal against the pump track for leak containment and controlled waste through the pumphead waste port in the event of a tube failure. For operator and environmental safety, pumps without clear viewing windows and/or waste port are not acceptable.
3. Rotor assembly shall be equipped with two compression rollers, which shall be retractable for tube loading, SIP, or CIP flushing cycles. Compression rollers shall be located 180 degrees apart for compression of the tube against the track twice per rotor revolution. One roller shall at all times be fully engaged with the tubing providing complete compression to prevent backflow or siphoning. Occlusion gap shall come factory set to accommodate 3.2 mm wall thickness tube. To maximize pump efficiency, pumps without retractable rollers and/or more than 2 compressing rollers are not acceptable.
4. The rotor assembly shall be close coupled to the output shaft of the drive gear motor by a 19 mm keyed shaft and shall be axially secured to the shaft by a through center retaining screw. Pumphead track shall be secured to the drive via two slotted screws and shall be self-locating.
5. Material of Construction
 - a. Track: Aluminum, Trimite polyester powder coat, electrostatically applied and baked
 - b. Door:
 1. Inner Shell: Grilamid TR55
 2. Outer Shell: shock resistant Polyurethane
 3. Door Seal: Silicone
 4. Drain Port Adapter: Acetyl
 - c. Rotor:
 1. Hub & Roller Arms: Fortron 1140L4 (PPS)
 2. Hub Cover: Dupont Hytrel G5544
 3. Main Rollers: 304SS
 4. Main Roller Bearings: Carbon Steel (sealed)
 5. Guide Rollers: Nylatron

6. Hardware & leaf springs: 304SS

B. Tubing

1. Pump tubing shall be in contact with the inside diameter of the track (housing) through an angle of 180 degrees and be held in place on the suction and discharge by tube retainer clamps. The tubing shall be replaceable without the use of tools and with no disassembly of the pumphead. To achieve maximum flow per revolution, pump heads with a track angle of less than 180 degrees are not acceptable. See 1.02.
2. Pump tubing shall be constructed of Marprene II, a thermoplastic elastomer with a 64 Shore A durometer and 3.2mm wall thickness. Pump manufacturer must manufacture Marprene tubing in-house. Pump manufacturers who purchase third party tubing are not acceptable.
3. Pump shall readily accept tubing ID's of 6.4mm, 9.6mm, 12.7mm or 15.9mm without pump adjustment or replacement. Tubing with a wall thickness less than 3.2mm is not acceptable. See 1.02.
4. Supply 15-meter roll of specified tubing size.

C. Drive

1. Rating: Continuous 24 hour operation, 40° C ambient.
2. Supply: 110-120V 50/60 Hz and 220-240V 50/60 Hz, 1-Phase field switch able. Supply nine-foot length mains power cord with standard 115V three-prong plug.
3. Max drive power consumption: 250VA.
4. Enclosure: NEMA 4X
5. Housing: Pressure cast aluminum with Alocrom pre-treatment and exterior grade corrosion resistant polyester powder coat. By nature of the environmental conditions, unpainted housings, including 316SS, are not acceptable.
6. Pumps must meet the following minimum requirements for operator interface functionality. Pumps not meeting this minimum functionality will not be accepted.
 - a. Backlit graphical LCD capable of up to four lines of text with up to 16 characters per line to display pump speed, running status, flow rate, and programming instructions
 - b. Keypad for start, stop, speed increment, speed decrement, forward/reverse direction, rapid prime, and programming.
 - c. Menu driven on screen programming of manual control, flow, and general programming.
 - d. Programmable "Auto Restart" feature to resume pump status in the event of power outage interruption.
 - e. Programmable "Keypad Lock" to allow operator lockout of all keys except emergency start/stop.
 - f. Programmable "Maximum Speed" to allow operator to set the maximum speed of the pump within 0.1-265 rpm.
7. Drive motor- brushless DC motor with integral gearbox and tachometer feedback.
 - a. Speed Control Range of 2650:1 from 0.1 to 265 rpm +/- 0.1 rpm throughout the range.
 - b. Closed loop microprocessor controlled drive with pulse width modulation at speeds above 35 rpm and synchronous mode with magnetic field rotation control below 35 rpm
 - c. Circuitry complete with temperature and load compensation and protection.
8. Mounting: Drive shall be self-supporting and shall not require anchoring.
9. Chemical Resistant Metering Pump Shelf (Optional)
 - a. Material of Construction: Polypropylene

- b. Mounting Hardware & Installation to be supplied by the Contractor

D. Spares

- 1. Supply one spare pump head assembly.

***(Under 2.03.B.3 one 15-meter pack of tubing is provided for each different chemical service. For regular preventative maintenance and normal corrective maintenance, only tubing need be stocked and is supplied with the pump in sufficient quantity for this purpose. For additional corrective maintenance, it is advisable to have a spare pump head stocked.)**

Part 3 – Execution

3.01 Installation (By Contractor)

- A. Contractor shall install items in accordance with manufacturer's printed instructions and as indicated and specified.
- B. Contractor to supply hose barb-to-process line adapters for connection of pump tubing to process lines. Hose barbs to be secured to the pump tubing via a hose clamp tightened around the OD of the tubing.